

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7300-1637:0101

CATEGORY: 7300 -- MISC. DEVICE/CONTROL UNIT ACCESSORIES

LISTEE: HONEYWELL POWER PRODUCTS, 12 Clintonville Road, Northford, CT 06472
Contact: Yogesh Shah (203) 484-1200 Fax (203) 484-7309
Email: yogesh.shah@honeywell.com

DESIGN: Models HP-300/-400/-600 series power supplies. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Input: 120 V ac, 1.4 A
Output: 12 V dc or 24 V dc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as power supplies for use with separately listed compatible fire alarm control units and indicating devices. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

10-03-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division